



- ROOF PLAN NOTES:
- TOP OF CONCRETE SLAB SHOWN AS THIS
 - SLAB NOTES:
 - CONCRETE SLAB REINF. W/ #4 AT 12" AS TEMP. REINF. PERPENDICULAR TO MAIN BOTTOM REINF. IN ADDITION TO TOP & BOTTOM BARS SHOWN ON PLANS.
 - SLAB NOTES:
 - CONCRETE SLAB REINF. W/ #4 AT 12" AS TEMP. REINF. PERPENDICULAR TO MAIN BOTTOM REINF. IN ADDITION TO TOP & BOTTOM BARS SHOWN ON PLANS.
 - FOR GENERAL STRUCTURAL NOTES SEE SHEET S-1
 - FOR TYPICAL DETAILS, REFER TO SHEETS S-4
 - FOR CONCRETE BEAM SCHEDULE, SEE SHEET S-1
 - FOR EXACT LOCATION OF ANY OPENING AND/OR EQUIPMENT, COORDINATE WITH ARCHITECTURAL, MECHANICAL AND ELECTRICAL DRAWINGS.
 - EXTERIOR CEILING TO BE W/ STUCCO OVER METAL LATH OVER 3/4" FELT PAPER OVER 5/8" PLYWOOD SHEATHING OVER PRE-FAB. WOOD TRUSSES W/ 8d NAILS @ 6" c/c.
 - COORDINATE ALL FLOOR SLOPES AND ELEVATIONS WITH ARCHITECTURAL DRAWINGS.
 - LEADER "A" DENOTES (2) 2"x10" P.T. WOOD SOUTHERN PINE#2 R FASTENED TO CONC. W/ 3/8" HILTI KIMB BOLTS 3 @ 12" O.C. STAGGERED & 1/2" MIN. EMBEDMENT. FULL CELL W/ GROUT.
 - FOR RTU UNITS SUPPORT SEE DETAIL C/S-4
 - DIAPHRAGM NAILING PATTERN AS PER DETAIL BELLOW

GENERAL CONTRACTOR SHALL COORDINATE ALL EXISTING CONDITIONS AND DIMENSIONS PRIOR TO START ANY WORK. CONTACT E.O.R. IMMEDIATELY IF ANY DISCREPANCIES BETWEEN EXISTING CONDITIONS AND THESE DRAWINGS.

- CONSTRUCTION SEQUENCE AT THE NEW ELEVATOR:
- FOUNDATION WORK FOR NEW FOOTINGS. SEE PLAN.
 - SHORING OF ALL ELEVATED STRUCTURE.
 - INSTALLATION OF NEW STEEL BEAMS.
 - REMOVAL OF EXISTING CONCRETE SLAB AND EXISTING BEAM ON SECOND FLOOR FRAMING PLAN MADE ARE ON SECOND FLOOR FRAMING PLAN MADE
 - FORMING AND POURING OF NEW CONCRETE SLAB.
 - G.C. TO SUBMIT SPLICING G.C. DETAIL DRAWINGS AT STEEL SHOP DRAWINGS FOR E.O.R. APPROVAL

ROOF FRAMING PLAN

SCALE: 1/8" = 1'-0"

RAMOSMARTINEZ
ARCHITECTS, INC. AA 26000528

MIAMI: 521 N.W. 12th AVENUE, MIAMI, FL 33136
TELEPHONE: 305-548-3006
FACSIMILE: 305-548-3008
WEBSITE: www.rmag.com

NEW YORK: 11 FINE STREET, JERSEY CITY, NJ 07302

First Haitian Free Church of Nazarene by Faith

ORLANDO, FLORIDA

388 SOUTH ORANGE BLOSSOM TRAIL, ORLANDO, FLORIDA

Group: 3401 NW 22nd Ave, Suite 300
P: (305) 598-8153
F: (305) 598-0076
www.essential.com

REVISIONS: RISSA LOPEZ, P.E., LIC. NO. 58389
GONCALO PAZ, P.E., LIC. NO. 80734

Building Department Comments 10-26-09

CONC. NO. 60102
DATE: 07/24/08
DRAWN BY:
CHECKED BY:

S-3
3 of 7

ROOF FRAMING PLAN AND DETAILS.