




L EXISTING TB REINF. AT OPENING.
 SCALE: 3/4" = 1'-0"




L EXISTING TB REINF. AT OPENING.
 SCALE: 3/4" = 1'-0"




H DET. OF PERMANENT LATERAL BRACING OF TRUSS
 SCALE: 1/4" = 1'-0"




J TYPICAL LATERAL BRACE SPLICE
 SCALE: 1/4" = 1'-0"



K PLYWOOD NAILING DETAIL
 SCALE: 1/4" = 1'-0"




ROOF WIND PRESSURES
 N.T.S.



FOR WINDS:
 WINDWARD WALL PRESSURES: 17.38 PSF
 LEeward WALL PRESSURES: -12.25 PSF
 ROOF PRESSURE COEFF. (Cp) = 0.88
 WIND PRESSURE COEFF. ZONE: 0.88
 INTERNAL PRESSURE COEFF. (Cpi) = +0.18
 OR
 Cp = 0.1 X WIDTH = 13.4
 Cp = 0.4 X HEIGHT = 10.8 NOT LESS THAN 0.88
 USE Cp = 10.8 FEET

ZONE 1		ZONE 2		ZONE 3		ZONE 4	
AREA	PRESSURE	AREA	PRESSURE	AREA	PRESSURE	AREA	PRESSURE
10SF	-25.1 PSF	10SF	36.06 PSF	10SF	-46.63 PSF	10SF	-20.55 PSF
20SF	-24.4 PSF	20SF	35.42 PSF	20SF	-46.63 PSF	20SF	-22.91 PSF
50SF	-23.6 PSF	50SF	34.58 PSF	50SF	-29.74 PSF	50SF	-21.90 PSF
ZONE 2		ZONE 3		ZONE 4		ZONE 5	
AREA	PRESSURE	AREA	PRESSURE	AREA	PRESSURE	AREA	PRESSURE
10SF	-42.0 PSF	10SF	-9.3 PSF	10SF	-20.55 PSF	10SF	-20.55 PSF
20SF	-41.3 PSF	20SF	-9.3 PSF	20SF	-20.55 PSF	20SF	-20.55 PSF
50SF	-31.0 PSF	50SF	-9.3 PSF	50SF	-20.55 PSF	50SF	-20.55 PSF



E THICKENED EDGE DETAIL
 SCALE: 3/16" = 1'-0"

